

Labino AB

Fågelsångsvägen 16

186 42 Vallentuna

Classification of light source in accordance with IEC / SS-EN 62471^(1 appendix)

RISE Research Institutes of Sweden has performed classification of a light source in accordance with SS-EN 62471:2008.

Test object

UVG2 2.0 Mid

Classification

The light source tested belongs to *Risk Group 3 (High Risk)* during normal operation.

Identification

Reference: Lisel Athanasiadis

Date of arrival: December 2020

Manufacturer: Labino AB

Type: UVG2 2.0 Mid, s/n: 64873

Date of measurement

January 11-28, 2021.

Test conditions

Measurements were carried out in a temperature-stabilized laboratory with the temperature $23\text{ °C} \pm 2\text{ °C}$.

Measurements of radiance/irradiance were made at a distance of 200 mm from the lamp front surface, which is considered appropriate for the application at hand. Measurements were made in the wavelength range 250 nm to 800 nm. No significant radiation was detected outside this range.

Instruments

Spectroradiometer Optronic 756 inv.no. 901723

Picoammeter Keithley 6485/E inv.no. 603159

Silicon detector inv.no. 500963

Test method

Applicable parts of SS-EN 62471:2008 and RISE Method 4432.

RISE Research Institutes of Sweden AB

Postal address

Box 857
SE-501 15 BORÅS
Sweden

Office location

Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail

+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Test result light source UVG2 2.0 Mid

The spectral content for the light source is shown in figure 1 below. No significant radiation was detected outside the shown range.




Figure 1. Spectral irradiance.

Table 1. Summary of results based on irradiance measurement.

Hazard name	Wavelength range (nm)	Exposure duration (s)	Limiting aperture (rad)	Exposure limit Risk Group 2 (W/m²)	Measurement value (W/m²)
Actinic UV skin & eye E_s	200 - 400	1000	1.4	3.0×10^{-2}	3.9×10^{-2}
Eye UV-A E_{UVA}	315 - 400	100	1.4	100,0	386.2
Blue-light small source E_B	300 - 700	0,25	<0.011	N/A	N/A
Eye IR E_{IR}	780 - 3000	10	1.4	N/A	N/A
Skin thermal E_H	380 - 3000	10	2π sr	3557	16

Table 2. Summary of results based on radiance measurement.

Hazard name	Wavelength range (nm)	Exposure duration (s)	Limiting aperture (rad)	Exposure limit Risk Group 1 (W/m ²)	Measurement value (W/m ² sr)
Blue light L_B	300 - 700	10000	0.011	1.0×10^4	5.0×10^2
Retinal thermal L_R	380 - 1400	10	0.011	($\alpha = 0.1$) 2.8×10^5	1.2×10^3
Retinal thermal (weak visual stimulus) L_{IR}	780 - 1400	N/A	0.011	N/A	N/A

Results based on the irradiance and radiance measurement show that the light source should be classified as belonging to *Risk group 3*.

Measurement uncertainty

Radiance/Irradiance: $\pm 10\%$

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty of measurement has been determined in accordance with EA Publication EA-4/02.

Remark


The results in this report are only valid for the item tested. The classification has been done without considering the measurement uncertainties.

RISE Research Institutes of Sweden AB

Measurement Science and Technology - Time and Optics

Performed by

Examined by



Signed by: Ingemar Svensson
Reason: I am the author of this document
Date & Time: 2021-02-09 09:16:58 +01:00

Ingemar Svensson



Signed by: Stefan Källberg
Reason: I have reviewed this document
Date & Time: 2021-02-09 11:00:45 +01:00

Stefan Källberg

Appendix

Appendix 1

Photo of the test object

Labino AB

Fågelsångsvägen 16

186 42 Vallentuna

Classification of light source in accordance with IEC / SS-EN 62471^(1 appendix)

RISE Research Institutes of Sweden has performed classification of a light source in accordance with SS-EN 62471:2008.

Test object

UVG2 2.0 Spot

Classification

The light source tested belongs to *Risk Group 3 (High Risk)* during normal operation.

Identification

Reference: Lisel Athanasiadis

Date of arrival: December 2020

Manufacturer: Labino AB

Type: UVG2 2.0 Spot, s/n: 64872

Date of measurement

January 11-28, 2021.

Test conditions

Measurements were carried out in a temperature-stabilized laboratory with the temperature $23\text{ °C} \pm 2\text{ °C}$.

Measurements of radiance/irradiance were made at a distance of 200 mm from the lamp front surface, which is considered appropriate for the application at hand. Measurements were made in the wavelength range 250 nm to 800 nm. No significant radiation was detected outside this range.

Instruments

Spectroradiometer Optronic 756 inv.no. 901723

Picoammeter Keithley 6485/E inv.no. 603159

Silicon detector inv.no. 500963

Test method

Applicable parts of SS-EN 62471:2008 and RISE Method 4432.

RISE Research Institutes of Sweden AB

Postal address

Box 857
SE-501 15 BORÅS
Sweden

Office location

Brinellgatan 4
SE-504 62 BORÅS

Phone / Fax / E-mail

+46 10 516 50 00
+46 33 13 55 02
info@ri.se

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

Test result light source UVG2 2.0 Spot

The spectral content for the light source is shown in figure 1 below. No significant radiation was detected outside the shown range.




Figure 1. Spectral irradiance.

Table 1. Summary of results based on irradiance measurement.

Hazard name	Wavelength range (nm)	Exposure duration (s)	Limiting aperture (rad)	Exposure limit Risk Group 2 (W/m²)	Measurement value (W/m²)
Actinic UV skin & eye E_s	200 - 400	1000	1.4	3.0×10^{-2}	4.6×10^{-2}
Eye UV-A E_{UVA}	315 - 400	100	1.4	100,0	438.0
Blue-light small source E_B	300 - 700	0,25	<0.011	N/A	N/A
Eye IR E_{IR}	780 - 3000	10	1.4	N/A	N/A
Skin thermal E_H	380 - 3000	10	2π sr	3557	14

Table 2. Summary of results based on radiance measurement.

Hazard name	Wavelength range (nm)	Exposure duration (s)	Limiting aperture (rad)	Exposure limit Risk Group 1 (W/m ²)	Measurement value (W/m ² sr)
Blue light L_B	300 - 700	10000	0.011	1.0×10^4	5.1×10^2
Retinal thermal L_R	380 - 1400	10	0.011	$(\alpha = 0.1)$ 2.8×10^5	1.2×10^3
Retinal thermal (weak visual stimulus) L_{IR}	780 - 1400	N/A	0.011	N/A	N/A

Results based on the irradiance and radiance measurement show that the light source should be classified as belonging to *Risk group 3*.

Measurement uncertainty

Radiance/Irradiance: $\pm 10\%$

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty of measurement has been determined in accordance with EA Publication EA-4/02.

Remark

The results in this report are only valid for the item tested. The classification has been done without considering the measurement uncertainties.

RISE Research Institutes of Sweden AB

Measurement Science and Technology - Time and Optics

Performed by

Examined by



Ingemar Svensson

Signed by: Ingemar Svensson
Reason: I am the author of this document
Date & Time: 2021-02-09 09:16:41 +01:00



Stefan Källberg

Signed by: Stefan Källberg
Reason: I have reviewed this document
Date & Time: 2021-02-09 11:01:26 +01:00

Appendix

Appendix 1

Photo of the test object